



SINCE 1896

# REPORT

Intertek ETL SEMKO

3933 US ROUTE 11 CORTLAND, NEW YORK 13045

Order No. 3096540

Revision Date: August 23, 2006  
Original Issue Date: June 16, 2006

**REPORT NO. 3096540CRT-001a**

## **STATIC PRESSURE, SOUND POWER LEVEL, AREA FACTOR AND THROW TESTS ON SQUARE FOUR WAY CEILING DIFFUSERS**

**RENDERED TO**

**BEST CHOICE INDUSTRIES L.L.C.  
P. O. BOX 31567  
DUBAI, U.A.E.**

**NOTE:** Report revised to include watermark

### **INTRODUCTION**

This report gives the results of tests conducted on five Multicore Square Diffusers. The test results include Static Pressure, Area Factor, Throw and Sound Power Level. The samples were selected and supplied by the client and were received at the laboratories on May 5, 2006. The samples appeared to be in new unused condition upon receipt.

### **AUTHORIZATION**

Signed Intertek Quotation No. 19932299

### **TEST METHOD**

The diffusers were tested in accordance with the ASHRAE 70-1991 Standard "Method of Testing for Rating the Performance of Air Outlets and Inlets", which incorporates ADC 1062: GRD-84 Test Code for Grilles, Registers and Diffusers. Acoustical data was obtained employing a Brüel & Kjaer Digital Frequency Analyzer Type 2131 and analyzed on a CompuAdd 286 Computer and Epson LQ-850 printer. The reference sound source used for this test was a calibrated Brüel & Kjaer Type 4204, which conforms to the above standard. The octave band sound power levels were plotted on graph of Noise Criteria Curves which is in the ADC Test Code. These curves are reprinted with permission from the ASHRAE Handbook and Product Directory, 1976. Each diffuser was installed in the facility and supplied with measured volumes of air. The static pressure was measured 1½ duct diameters upstream of each diffuser inlet.

An independent organization testing for safety, performance, and certification.

This report is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this report. Only the Client is authorized to copy or distribute this report and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results in this report are relevant only to the sample tested. This report by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program. Measurement uncertainty budgets have been determined for applicable test methods and are available upon request.

**DESCRIPTION OF TEST SPECIMENS**

The four multicore square ceiling diffusers were constructed from aluminum. The back of each diffuser had a square opposed blade damper attached to the inlet. Five square neck sizes were used for the testing; 150, 225, 300, 375, and 450 millimeter. The multicore face of each 4-way throw diffuser consisted of deflector blades, starting in the center with a 75 mm square and each additional square being 75 mm larger than the previous. The size 150 had one additional blade, whereas the size 450 had five additional blades. The opposed blade dampers were in the full open position for all of the testing.

**RESULTS OF TESTS**

Octave Band Center Frequency Hertz	<b>SAD 4WS 150 X 150 Square Ceiling Diffuser</b> <u>Discharge Sound Power Level dB re 10<sup>-12</sup> Watt</u>				
125	43.0	45.0	48.0	50.0	51.5
250	38.5	41.0	44.0	47.0	49.0
500	33.5	36.5	40.0	43.0	45.5
1000	24.5	30.5	35.5	40.5	47.5
2000	21.0*	24.0	30.5	36.5	48.0
4000	22.0*	22.0*	22.0*	26.0	31.0
8000	28.0*	28.0*	28.0*	28.0*	28.0*
Supply Air Volume, CFM	300	350	400	450	500
Inlet Static Pressure, in. H <sub>2</sub> O	0.080	0.110	0.142	0.180	0.225
**Noise Criteria (NC)	17	21	24	30	39

\* Sound Power Level data has reached ambient levels in the test room or is determined by instrument limitations. Actual levels are less than or equal to the levels indicated.

\*\* Noise Criteria ratings were determined by subtracting a room absorption of 10dB from the Sound Power Level data.


Checked by 

**RESULTS OF TESTS (cont'd)**

<u>Octave Band Center Frequency Hertz</u>	<b>SAD 4WS 225 X 225 Square Ceiling Diffuser</b> <u>Discharge Sound Power Level dB re 10<sup>-12</sup> Watt</u>						
125	42.0	44.0	47.5	50.0	52.0	54.5	56.0
250	40.0	42.5	45.5	48.0	50.5	52.5	55.5
500	35.5	40.0	44.0	47.5	50.0	51.5	53.5
1000	28.0	33.5	39.5	44.0	48.5	52.0	55.5
2000	22.5*	26.0	33.5	39.0	44.0	47.5	51.5
4000	21.5*	21.5*	23.0*	28.5	34.0	39.0	44.0
8000	27.5*	27.5*	27.5*	28.0*	28.0*	28.5	32.5
Supply Air Volume, CFM	250	300	350	400	450	500	550
Inlet Static Pressure, in. H <sub>2</sub> O	0.070	0.100	0.138	0.180	0.225	0.280	0.340
**Noise Criteria (NC)	18	25	29	33	37	41	45
<u>Octave Band Center Frequency Hertz</u>	<b>SAD 4WS 300 X 300 Square Ceiling Diffuser</b> <u>Discharge Sound Power Level dB re 10<sup>-12</sup> Watt</u>						
125	45.0	46.5	48.5	51.0	52.0	54.5	56.5
250	41.0	43.0	45.5	47.0	48.5	50.5	52.5
500	37.0	40.0	43.0	45.5	47.0	49.5	51.0
1000	28.5	33.0	36.5	40.5	43.0	46.0	49.0
2000	22.5*	25.0	30.5	35.5	38.5	42.5	45.5
4000	21.5*	21.5*	22.0*	24.0	27.0	31.5	35.0
8000	27.5*	27.5*	27.5*	27.5*	27.5*	28.0*	28.5*
Supply Air Volume, CFM	400	450	500	550	600	650	700
Inlet Static Pressure, in. H <sub>2</sub> O	0.075	0.094	0.116	0.138	0.162	0.192	0.225
**Noise Criteria (NC)	21	24	28	31	32	35	38

\* Sound Power Level data has reached ambient levels in the test room or is determined by instrument limitations. Actual levels are less than or equal to the levels indicated.

\*\* Noise Criteria ratings were determined by subtracting a room absorption of 10dB from the Sound Power Level data.

Checked by: 

**RESULTS OF TESTS (cont'd)**

<u>Octave Band Center Frequency Hertz</u>	<b>SAD 4WS 375 X 375 Square Ceiling Diffuser</b> <u>Discharge Sound Power Level dB re 10<sup>-12</sup> Watt</u>					
125	42.0	45.0	46.5	49.5	51.5	54.0
250	37.5	41.0	43.0	46.0	48.5	51.0
500	33.0	39.5	42.5	46.0	48.5	51.0
1000	23.5	30.0	34.5	40.5	45.0	49.5
2000	21.0*	22.5*	27.5	34.0	39.0	44.0
4000	21.5*	21.5*	21.5*	23.5*	27.5	33.0
8000	27.5*	27.5*	27.5*	27.5*	27.5*	27.5*
Supply Air Volume, CFM	500	600	700	800	900	1000
Inlet Static Pressure, in. H <sub>2</sub> O	0.052	0.072	0.100	0.130	0.160	0.200
**Noise Criteria (NC)	17	24	27	31	34	39
<u>Octave Band Center Frequency Hertz</u>	<b>SAD 4WS 450 X 450 Square Ceiling Diffuser</b> <u>Discharge Sound Power Level dB re 10<sup>-12</sup> Watt</u>					
125	39.0*	41.5	47.0	52.0	57.0	
250	36.0	39.5	45.5	49.5	54.0	
500	29.5	35.5	45.0	50.0	54.0	
1000	23.0	26.0	37.5	45.0	52.5	
2000	21.0	23.0	30.0	39.5	47.0	
4000	21.0*	21.5*	21.5*	28.5	37.0	
8000	27.5*	27.5*	27.5*	27.5*	28.5*	
Supply Air Volume, CFM	600	750	1000	1250	1500	
Inlet Static Pressure, in. H <sub>2</sub> O	0.034	0.052	0.094	0.145	0.208	
**Noise Criteria (NC)	<15	20	30	35	42	

\* Sound Power Level data has reached ambient levels in the test room or is determined by instrument limitations. Actual levels are less than or equal to the levels indicated.

\*\* Noise Criteria ratings were determined by subtracting a room absorption of 10dB from the Sound Power Level data.

Checked by:

AREA FACTOR  $A_k$ 

## FOR AIR OUTLETS AND AIR INLETS

**Model: SAD 4WS 150 x 150**

Manufacturer: Best Choice Industries

Throw Dir.: Horizontal

Flow Meter: Nozzle Metering Station

Inlet Size: 140 mm X 140 mm

Neck Area (Sq. Ft.): 0.211

Anemometer: Alnor Velometer Type 6000P

Serial Number: 6077AL

Run Number	Readings				Calculations				
	Anemometer - (V <sub>k</sub> , FPM)				Static "H <sub>2</sub> O	Q <sub>2</sub> Flow CFM	Neck Velocity	Total Pressure	Area Fact. A <sub>k</sub>
	1	2	3	4	Average				
1	680	700	700	700	695	0.009	100	474	0.014
2	1325	1350	1350	1350	1344	0.036	200	948	0.056
3	1950	1950	2000	2000	1975	0.080	300	1422	0.126
								Average: 0.148	

Checked by: 

Intertek ETL SEMIKO

		Air Volume: 200 CFM						Inlet Static Pressure: 0.036"									
		Distance From Diffuser (Ft)															
Distance From Ceiling Inches		1'	2'	3'	4'	5'	6'	7'	8'	9'	10'	11'	12'	13'	14'	15'	16'
1"	445	400	375	320	285	240	205	175	140	120	100	90	80	65	55	45	
3"	95	110	150	170	160	150	145	140	125	110	95	90	85	70	60	55	
6"	30	35	40	35	65	80	90	80	75	70	65	60	60	60	60	50	
9"	20	30	30	40	30	35	40	45	40	50	55	60	55	55	50	40	
12"	35	20	15	15	15	15	15	25	25	20	30	25	20	20	25	35	
18"	30	15	10	15	15	15	15	20	20	20	20	20	20	15	20	30	
24"	30	20	15	10	10	15	15	15	20	20	20	20	20	20	20	20	
		Air Volume: 150 CFM						Inlet Static Pressure: 0.020"									
		Distance From Diffuser (Ft)															
Distance From Ceiling Inches		1'	2'	3'	4'	5'	6'	7'	8'	9'	10'	11'	12'	13'	14'	15'	15'
1"	435	350	290	220	175	145	120	105	95	75	75	65	55	50	50	45	
3"	80	80	85	95	90	85	80	75	75	70	65	65	50	50	45	45	
6"	20	35	25	40	35	50	55	55	50	50	45	40	35	30	30	35	
9"	15	15	25	20	25	20	40	25	35	30	35	35	30	30	25	30	
12"	15	15	15	20	30	30	30	20	25	20	25	25	25	25	20	20	
18"	15	10	20	15	15	20	15	15	25	25	20	15	15	20	15	20	
24"	15	10	10	15	10	15	10	15	15	15	15	15	10	15	10	10	
		Air Volume: 115 CFM						Inlet Static Pressure: 0.010"									
		Distance From Diffuser (Ft)															
Distance From Ceiling Inches		1'	2'	3'	4'	5'	6'	7'	8'	9'	10'	11'	12'	13'	14'	15'	15'
1"	355	265	195	145	135	120	105	90	70	65	60	55	50	40	30	35	
3"	65	70	75	70	70	65	60	60	55	55	50	45	40	35	35		
6"	40	15	20	30	30	30	40	45	40	40	35	30	30	35	30		
9"	40	15	20	30	30	30	40	45	40	40	35	30	30	35	30		
12"	35	15	15	15	15	20	20	20	20	20	20	20	20	20	25	15	
18"	35	15	15	15	15	20	20	20	20	20	20	20	20	20	25	15	
24"	30	10	10	10	10	10	15	15	15	15	10	15	10	10	20	15	

Checked by: 

ETL SEMIKO  


**AREA FACTOR A<sub>k</sub>****FOR AIR OUTLETS AND AIR INLETS****Model: SAD 4WS 225 x 225**

Manufacturer: Best Choice Industries

Throw Dir.: Horizontal

Flow Meter: Nozzle Metering Station

Inlet Size: 215 mm x 215 mm

Neck Area (Sq. Ft.): 0.498

Anemometer: Alnor Velometer Type 6000P

Serial Number: 6077AL

Run Number	Readings				Calculations					
	1	2	3	4	Static "H <sub>2</sub> O	Q2 Flow CFM	Neck Velocity	Neck V.P.	Total Pressure	Area Fact. A <sub>k</sub>
1	1125	1125	1150	1125	1131	0.070	250	502	0.016	0.086
2	1550	1500	1550	1525	1525	0.138	350	703	0.031	0.169
3	2150	2100	2150	2138	2138	0.280	500	1004	0.063	0.343
									Average: 0.228	0.234

Checked by: **Intertek ETL SEMKO**

**BCI SAD 225 X 225**

		Air Volume: 300 CFM						Inlet Static Pressure: 0.101"								
		Distance From Diffuser (Ft)														
		2'	3'	4'	5'	6'	7'	8'	9'	10'	11'	12'	13'	14'	15'	16'
1"		550	550	485	350	260	230	190	180	145	120	100	95	85	75	70
3"		355	355	260	185	180	160	150	145	130	110	100	90	80	70	65
6"		55	50	75	75	95	100	95	90	85	80	75	70	65	60	55
9"		35	30	35	35	40	55	60	50	50	50	50	45	45	50	50
12"		30	25	30	30	30	30	30	35	40	35	40	35	40	35	30
18"		25	20	25	30	25	30	30	25	30	25	20	20	20	30	25
24"		25	20	30	30	30	30	25	25	30	25	20	20	25	20	30

		Air Volume: 220 CFM						Inlet Static Pressure: .055"								
		Distance From Diffuser (Ft)														
		2'	3'	4'	5'	6'	7'	8'	9'	10'	11'	12'	13'	14'	15'	
1"		425	375	290	225	195	160	140	120	100	95	80	75	65	55	50
3"		100	115	130	145	135	125	110	105	95	90	80	75	60	50	50
6"		45	30	45	45	50	60	65	65	60	55	55	50	45	45	40
9"		35	25	20	20	30	30	25	30	35	35	40	30	30	35	30
12"		35	20	15	15	15	15	25	25	25	20	30	25	20	20	25
18"		30	15	10	15	15	15	15	20	20	20	20	25	20	15	20
24"		30	20	15	10	10	15	15	15	20	20	20	20	20	20	15

		Air Volume: 140 CFM						Inlet Static Pressure: 0.022"								
		Distance From Diffuser (Ft)														
		2'	3'	4'	5'	6'	7'	8'	9'	10'	11'	12'	13'	14'	15'	
1"		275	245	190	170	145	120	105	90	75	70	65	55	40	40	40
3"		50	45	35	55	55	65	75	60	50	45	40	35	30	35	30
6"		40	35	20	30	30	40	45	40	40	20	20	15	20	25	15
9"		35	15	15	15	15	20	20	20	15	10	15	10	10	20	15
12"		30	10	10	10	10	15	15	15	10	5	10	10	15	10	10
18"		25	10	10	5	5	10	15	15	10	10	10	10	10	10	10
24"		25	10	5	5	10	15	15	10	10	10	10	10	10	10	10

Checked by: 



**AREA FACTOR  $A_k$** **FOR AIR OUTLETS AND AIR INLETS****Model: SAD 4WS 300 x 300**

Manufacturer: Best Choice Industries

Throw Dir.: Horizontal

Flow Meter: Nozzle Metering Station

Inlet Size: 290 mm x 290 mm

Neck Area (Sq. Ft.): 0.905

Anemometer: Alnor Velometer Type 6000P

Serial Number: 6077AL

Date: May 18, 2006  
Air Density: 0.070 lbs/ft<sup>2</sup>

Run Number	Readings				Calculations			
	1	2	3	4	Static "H <sub>2</sub> O	Q2 Flow CFM	Neck Velocity	Neck V.P.
1	1200	1150	1200	1175	0.094	450	497	0.015
2	1525	1550	1575	1550	0.162	600	663	0.028
3	2000	1950	2000	1950	0.260	750	829	0.043
								Average: 0.383

Checked by: **Intertek ETL SEMKO**

Distance From Ceiling Inches

**Air Volume: 300 CFM**

	2'	3'	4'	5'	6'	7'	8'	9'	10'	11'	12'	13'	14'	15'
1"	390	365	340	270	240	205	170	150	140	120	110	100	95	85
3"	295	260	240	220	210	185	170	145	140	125	115	105	95	85
6"	100	175	195	190	155	150	135	110	100	90	80	75	70	60
9"	30	30	55	75	85	90	75	70	65	65	60	60	55	50
12"	25	25	30	35	40	45	50	45	40	40	50	55	45	45
18"	25	25	25	20	25	20	25	25	25	20	30	30	30	25
24"	25	20	25	20	25	20	20	20	20	20	20	20	25	25

Distance From Ceiling Inches

**Air Volume: 240 CFM**

	2'	3'	4'	5'	6'	7'	8'	9'	10'	11'	12'	13'	14'	15'
1"	320	290	275	240	215	170	145	130	110	105	90	80	70	60
3"	240	230	225	210	195	150	130	120	105	100	95	85	70	65
6"	80	120	165	150	145	125	115	90	85	75	70	70	65	55
9"	30	25	50	55	65	70	65	60	55	50	55	50	50	40
12"	30	25	25	30	35	45	40	35	30	30	45	30	40	35
18"	25	20	15	20	20	25	20	25	20	10	35	25	30	20
24"	25	15	15	20	20	20	20	20	20	15	25	20	15	15

Distance From Ceiling Inches

**Air Volume: 180 CFM**

	2'	3'	4'	5'	6'	7'	8'	9'	10'	11'	12'	13'	14'	15'
1"	275	240	210	180	150	130	100	95	85	80	70	65	55	50
3"	205	160	140	135	120	115	90	85	80	75	70	65	60	50
6"	30	50	80	105	100	95	70	65	55	55	50	50	45	40
9"	20	15	25	45	55	55	45	40	35	35	40	35	40	30
12"	15	15	15	20	30	30	20	25	20	25	25	25	25	20
18"	15	10	10	15	15	15	15	15	15	15	20	15	20	15
24"	15	10	10	10	15	15	15	15	15	15	10	15	10	10

Distance From Ceiling Inches

**Inlet Static Pressure: 0.042"**

	2'	3'	4'	5'	6'	7'	8'	9'	10'	11'	12'	13'	14'	15'
1"	390	365	340	270	240	205	170	150	140	120	110	100	95	85
3"	295	260	240	220	210	185	170	145	140	125	115	105	95	85
6"	100	175	195	190	155	150	135	110	100	90	80	75	70	60
9"	30	30	55	75	85	90	75	70	65	65	60	60	55	50
12"	25	25	30	35	40	45	50	45	40	40	50	55	45	40
18"	25	25	25	20	25	20	25	25	20	20	30	30	30	25
24"	25	20	25	20	25	20	20	20	20	20	20	20	25	25

Distance From Ceiling Inches

**Inlet Static Pressure: 0.027"**

	2'	3'	4'	5'	6'	7'	8'	9'	10'	11'	12'	13'	14'	15'
1"	320	290	275	240	215	170	145	130	110	105	90	80	70	60
3"	240	230	225	210	195	150	130	120	105	100	95	85	70	65
6"	80	120	165	150	145	125	115	90	85	75	70	70	65	55
9"	30	25	50	55	65	70	65	60	55	50	55	50	50	40
12"	30	25	25	30	35	45	40	35	30	30	45	30	40	35
18"	25	20	15	20	20	25	20	25	20	10	35	25	30	20
24"	25	15	15	20	20	20	20	20	20	15	25	20	15	15

Distance From Ceiling Inches

**Static Pressure: 0.015"**

	2'	3'	4'	5'	6'	7'	8'	9'	10'	11'	12'	13'	14'	15'
1"	275	240	210	180	150	130	100	95	85	80	70	65	55	50
3"	205	160	140	135	120	115	90	85	80	75	70	65	60	50
6"	30	50	80	105	100	95	70	65	55	55	50	50	45	40
9"	20	15	25	45	55	55	45	40	35	35	40	35	40	30
12"	15	15	15	20	30	30	20	25	20	25	25	25	25	20
18"	15	10	10	15	15	15	15	15	15	15	20	15	20	15
24"	15	10	10	10	15	15	15	15	15	15	10	15	10	10

Checked by:



**AREA FACTOR  $A_k$** **FOR AIR OUTLETS AND AIR INLETS****Model: SAD 4WS 375 x 375**

Manufacturer: Best Choice Industries

Throw Dir.: Horizontal

Flow Meter: Nozzle Metering Station

Inlet Size: 365 mm x 365 mm

Neck Area (Sq. Ft.): 1.434

Anemometer: Alnor Velometer Type 6000P

Serial Number: 6077AL

Date: May 18, 2006

Air Density: 0.070 lbs/ft<sup>2</sup>

Run Number	Readings				Calculations				Area Fact. A <sub>k</sub>
	Anemometer - (V/k, FPM)				Static "H <sub>2</sub> O	Q2 Flow CFM	Neck Velocity	Neck V.P.	
1	1	2	3	4	Average				
1	900	925	950	950	931	0.051	500	349	0.008
2	1250	1300	1275	1275	1275	0.100	700	488	0.015
3	1850	1900	1900	1850	1875	0.205	1000	697	0.030
								Average: 0.540	


  
Checked by


  
Intertek ETL SEMKO

**BCI 375X375**

Distance From Ceiling Inches	Air Volume: 250 CFM						Inlet Static Pressure: 0.012"							
	2'	3'	4'	5'	6'	7'	8'	9'	10'	11'	12'	13'	14'	15'
1"	270	240	200	175	150	125	115	105	100	95	75	70	70	60
3"	135	180	160	140	135	125	115	105	105	95	75	65	65	55
6"	30	80	90	90	90	90	80	80	75	70	65	60	60	50
9"	20	20	25	35	40	45	50	55	50	45	40	25	45	40
12"	15	15	20	20	20	20	30	30	40	35	30	30	30	30
18"	15	15	20	15	15	15	15	15	20	15	15	15	15	10
24"	15	15	20	15	15	15	15	15	10	15	15	15	15	10

Distance From Ceiling Inches	Air Volume: 200 CFM						Inlet Static Pressure: 0.080"							
	2'	3'	4'	5'	6'	7'	8'	9'	10'	11'	12'	13'	14'	15'
1"	200	195	180	145	130	105	95	85	70	60	55	50	45	45
3"	190	175	160	130	130	110	95	75	65	60	55	50	40	40
6"	35	60	80	95	95	85	70	70	60	55	50	40	30	40
9"	15	15	20	30	40	55	55	45	40	30	30	30	20	25
12"	15	15	15	15	15	30	25	30	15	20	15	15	15	15
18"	10	10	15	5	10	15	15	15	10	15	10	15	15	10
24"	5	10	10	5	10	15	15	10	10	10	10	10	10	10

Distance From Ceiling Inches	Air Volume: 150 CFM						Inlet Static Pressure: 0.045"							
	2'	3'	4'	5'	6'	7'	8'	9'	10'	11'	12'	13'	14'	15'
1"	185	160	150	130	115	95	80	75	65	55	50	45	40	30
3"	140	135	130	115	110	95	70	70	60	55	55	50	45	30
6"	25	40	70	75	70	65	50	50	40	45	40	35	30	20
9"	15	10	20	25	30	35	30	30	25	25	20	20	15	15
12"	10	10	10	10	10	20	15	15	15	15	15	15	15	10
18"	10	10	5	5	10	5	10	10	10	10	10	10	5	5
24"	10	10	5	5	10	5	10	5	10	10	10	10	5	10

Checked by: *[Signature]*
**Intertek SEMKO**

AREA FACTOR  $A_k$ 

## FOR AIR OUTLETS AND AIR INLETS

**Model: SAD 4WS 450 x 450**

Manufacturer: Best Choice Industries

Throw Dir.: Horizontal

Flow Meter: Nozzle Metering Station

Inlet Size: 440 mm X 440 mm

Neck Area (Sq. Ft.): 2.084  
Anemometer: Alnor Velometer Type 6000P

Serial Number: 6077AL

Run Number	Readings				Calculations					
	Anemometer - ( $V_k$ , FPM)				Static "H <sub>2</sub> O	Q2 Flow CFM	Neck Velocity	Neck V.P.	Total Pressure	Area Fact. $A_k$
1	1	2	3	4	Average					
1	900	925	900	900	906	0.052	750	360	0.008	0.060
2	1500	1550	1500	1525	1525	0.144	1250	600	0.023	0.167
3	1850	1825	1825	1850	1838	0.208	1500	720	0.033	0.241
Average: 0.821										

Note: This unit was too large for testing in the "throw terminal facility"

Checked by: ETL SEMKO  


## CONCLUSION

The test method employed for this test has no pass-fail criteria; therefore, the evaluation of the test results is left to the discretion of the client.

Date of Tests: May 16 through June 6, 2006

Report Approved By:



James R. Kline  
Engineer/Quality Supervisor  
Acoustical Testing

Report Reviewed By:



James H. Nickelsen  
Senior Project Engineer  
Acoustical Testing

Attachments: None